



UNELCO



ENGIE

Efaté Energy Road Map 2018-2030

Power Sector Development Pathway to
Achieving the Vanuatu Renewable Energy
Objectives

UNELCO in Efaté today ... in brief

Installed grid-connected capacity in Efaté (Sept. 2018)



3.6 MW



2.4 MWc



Up to
8 MW



Up to
20 MW

ÉFATÉ



Electricity
And Water


Customers: 16 000

Peak elec demand
12 MW

Generation: 66 GWh

The Vanuatu renewable energy (RE) commitments imply a 34 GWh increase in RE by 2020 and a 65 GWh total increase by 2030...

Currently deployed renewable gen., projected demand, and NERM/Paris Agreement commitments (Efaté; 2018, 2020*, 2030*; GWh/year)



... achieving these objectives will require a mix of renewable technologies; there are a handful of renewable resources available in Efaté and a certain number of criteria to consider when determining the target energy mix ...

Commercially/Technically viable Efaté Renewable Resources

Confirmed (with high potential)



Bio-fuels – sufficient local production to theoretically produce 2x Efaté’s elec. needs



Wind – Approx 1 860 h per year



PV Solar – Approx 1 380 h per year

Possible (but limited in scope)



Biomass/Incineration

Speculative/Unconfirmed exploitability



Geothermal – 4 to 6 MW

Strategic planning and renewable energy mix integration criteria

Pre-requisite: Availability of resource in Efaté (and in commercially viable range)

Technical

- Technical maturity
- Dispatchability/Intermittency

Economic

- Flexibility/Option value
- Overall Value for Vanuatu (“V4V”)
- Cost competitiveness

... all renewable technologies have their pros and cons, and the answer to meeting the renewable challenge will not be an “either/or” but rather an evolving “energy mix” in which intermittent energy will naturally have a place.

	TECHNICAL			ECONOMIC		
	Resource availability	Tech. Maturity	Dispat- chable	Option value	V4V	Cost Compe- titivness
	●	●	●	●	●	◐
	●	●	○	◑	◐	◑
	●	◑	◐	◐	◐	◑
	●	●	○	○	◑	●
	●	◑	◐	◐	◑	◑
	◑	◑	●	◐	●	◐
	?	◐	◑	○	◑	?

One technically and financially coherent scenario to reach 90% by 2030 could be the following RE energy mix ...

	CAPACITY		HOURS	Power Gen. 2030
	Existing	Additions		
	2.4 MWp	+ 7.4 MWp	x 1 380 h	= 13.5 GWh
	3.6 MW	+ 5.1 MWp	x 1 860 h	= 16.2 GWh
	0.0 MW	+ 0.5 MW	x 6 000 h	= 3.0 GWh
	8.0 MW	+ 0.0 MW	x 5 288 h	= 42.3 GWh
TOTAL	10.0 GWh			75.0 GWh


... the investment requirements would be significant and substantial donations will be paramount to achieving the objective without making the customer tariff unaffordable ...

	Capacity/Power added	“One-time” INVESTMENT	Recurrent FUEL + O&M
	7.4 MWp	1 365 M	50 M/year
	5.1 MW	1 480 M	75 M/year
	6.3 MWh	650 M	12 M/year
	0.5 MW	150 M	45 M/year
	14 Million liters per year	0 M	1 385 M/year
TOTAL		3 645 M	1 565 M/year

Avoided fossil fuel (per year)

- 17 M liters
- 45 120 tons of CO₂
- 1 650 M Vatus

... the resulting energy mix in 2030



In summary

In this scenario:

- Vanuatu would not only **meet its international climate commitment**, ensure **quasi-energy independence**, **reduce electricity cost volatility**, but also **sustainably re-inject 1.4 Billion Vatus per year into the local economy** (with a very high multiplier effect)
- **Development agencies would need to fund approximately 35 M USD in capex** for the PV Solar, Wind and Buffering/Storage
- **UNELCO would ensure the coordination of the implementation, the long-term O&M** of all the assets funded by the development agencies
- **Total coprah oil expenses would be sensibly similar to current oil expenditure, keeping the customer tariff similar to the one today.**
- **If development agencies help fund developments along the coprah oil value chain**, and UNELCO can therefore purchase coprah oil below the price of fossil fuels from aided producers, **the customer tariff could even decrease.**

APPENDIX

One technically and financially coherent scenario to reach 65% by 2020 could be the following RE energy mix ...


	CAPACITY		HOURS	Power Gen. 2020
	Existing	Additions		
	2.4 MWp	+ 5.7 MWp	x 1 380 h	= 10.6 GWh
	3.6 MW	+ 3.6 MWp	x 1 860 h	= 13.4 GWh
	0.0 MW	+ 0.5 MW	x 6 000 h	= 3.0 GWh
	8.0 MW	+ 0.0 MW	x 2 175 h	= 17.0 GWh
TOTAL	10.0 GWh	→		44.0 GWh

... the investment requirements would be significant and significant donations will be paramount to achieving the objective without making the customer tariff unaffordable ...

	Capacity/Power added	“One-time” INVESTMENT	Recurrent FUEL + O&M
	5.7 MWp	1 050 M	40 M/year
	3.6 MW	1 045 M	55 M/year
	4.5 MWh	465 M	10 M/year
	0.5 MW	150 M	45 M/year
	5 Million liters per year	0 M	490 M/year
TOTAL		2 710 M	640 M/year

Avoided fossil fuel
 (per year)
8.8 M Liters
23 600 tons CO₂
865 M Vatus/year

The NDC commitments imply an approx. 34 GWh increase in RE by 2020 and approx. 65 GWh increase in RE by 2030...




Notes:

* Projections of demand, hence commitment were established based on the assumption of a 2% p.a. growth of consumption

... the question now is how "best" to achieve the objective ...

Key local technical and economic parameters of PV Solar Generation (1/2)



ECONOMIC

PV solar

- Overnight investment 185 M Vatus / MWp
- Operations and Maintenance 7 M Vatus / MWp / year

Battery stabilisation

- Overnight investment 100 M Vatus / MWh
- Operations and Maintenance 2 M Vatus / MW / year

TECHNICAL


PV Solar

- Local generation nominal capacity in year 1 1 400 hours / year
- Average efficiency over lifetime of PV farm 90%
- Lifetime of PV solar farm 20-25 years
- Average generation per MWc 1 260 000 kWh / year / MWp

Battery stabilisation

- Requirement to “Firm” intermittent generation 0.85 MW useful storage capacity/MWp PV Solar
- Depth of discharge 80%
- Round-trip efficiency 98%
- Lifespan 10 years
- Nominal storage capacity required to “Firm” 1 MW nominal storage capacity/MWp PV Solar
- Nominal storage capacity in MWh 0.5 MWh / MWp PV Solar

Key local technical and economic parameters of PV Solar Generation (2/2)



For 1 MWp of firm PV Solar


PV Solar investment	22.2 M Vatus/year
+ Operations and Maintenance	7.0 M Vatus/year
+ Stabilisation investment	8.5 M Vatus/year
+ Operations and Maintenance	2.0 M Vatus /year

= TOTAL annual cost **39.7 M Vatus/year**

Total annual cost	39.7 M Vatus/year
/ Average generation	1.26 M kWh/year

= Estimated cost per kWh generated **31.5 Vatus/kWh**

Key local technical and economic parameters of cyclone resistant wind generation (1/2)



ECONOMIC

Wind

- Overnight investment 290 M Vatus / MW
- Operations and Maintenance 14.5 M Vatus / MW / year

Battery stabilisation

- Overnight investment 100 M Vatus / MWh
- Operations and Maintenance 2 M Vatus / MW / year

TECHNICAL


PV Solar

- Local generation nominal capacity in year 1 1 800 hours / year
- Lifetime of PV solar farm 20 years
- Average generation per MWc 1 800 000 kWh / year / MWp

Battery stabilisation

- Requirement to “Firm” intermittent generation wind 0.85 MW useful storage capacity/MW of
- Depth of discharge 80%
- Round-trip efficiency 98%
- Lifespan 10 years
- Nominal storage capacity required to “Firm” 1 MW nominal storage capacity/MW of wind

Key local technical and economic parameters of cyclone resistant wind generation (2/2)



For 1 MWp of firming Wind

Wind turbine investment	34.8 M Vatus/year
+ Operations and Maintenance	14.5 M Vatus/year
+ Stabilisation investment	8.5 M Vatus/year
+ Operations and Maintenance	2.0 M Vatus /year

= TOTAL annual cost **59.8 M Vatus/year**

Total annual cost	59.8 M Vatus/year
/Average generation	1.8 M kWh/year

= Estimated cost per kWh generated **33.2 Vatus/kWh**

Key local technical and economic parameters of Biofuel generation (1/2)



ECONOMIC

Bio-oil/fuel - Variable costs

- Low 23.5 Vatus/KWh generated
- Medium 29.4 Vatus/KWh generated
- High 35.3 Vatus/kWh generated

Fixed costs

- Investment + Operations + Maintenance 3.75 Vatus/kWh generated

TECHNICAL

Bio-fuel per GWh generated 294 000 liters/GWh generate

Key local technical and economic parameters of Biofuel generation (2/2)



For 1 GWh of biofuel generation

	LOW	MEDIUM	HIGH
Variable fuel cost (M Vt/GWh)	23.5	29.4	35.3
Non fuel generation costs (M Vt/GWh)	3.8	3.8	3.8

= TOTAL annual cost (M Vt/GWh)	27.3	33.2	39.6
Total annual cost (M Vt/GWh)	27.3	33.2	39.6
Generation (M kWh)	1.0	1.0	1.0

= Unit cost (Vatus/kWh)	27.3	33.2	39.6